



Compliance Statement

Screened Category 5e ISO/IEC, EN & ANSI/TIA Communication Cable

Krugel Exim Identification P/N KE300S24LS0H
Category 5e Overall Foil Screened
100 Ω , 4 Twisted Pairs, 24 AWG, Flame Retardant, LSHF, Copper Cable

Krugel Exim s.r.o.
Rybnicna 38/H
831 06 Bratislava 35, Slovak Republic

Compliance Statement No. 108441E

This Screened ISO/IEC, EN & ANSI/TIA Communication Cable has been tested by 3P Third Party Testing and complies with the Category 5 performance requirements of edition 2.2 of ISO/IEC Generic Cabling Standard 11801, CENELEC Generic Cabling Standard EN 50173-1:2011, the Category 5e requirements of ANSI/TIA Generic Cabling Standard 568-C.2, 2nd edition IEC Cable Standard 61156-5, incl. amendment 1 and the requirements of 2nd edition CENELEC Cable Standard EN 50288-2-1 and FprEN 50288-2-1:2012. Flame safety is verified according to IEC 60332-1-2, IEC 61034-1, IEC 61034-2, incl. amendment 1 and IEC 60754-2. The cable has EMC Performance Rating 9. The Compliance Statement may be suspended or withdrawn if cable fails to pass a Maintenance Testing performed at 6 or 12 month intervals.

Hoersholm, 19th March 2013

A handwritten signature in blue ink, appearing to read "Ole Lambertsen", is written over a horizontal line.

Ole Lambertsen
Test Responsible

Hoersholm, 19th March 2013

A handwritten signature in blue ink, appearing to read "Poul Villien", is written over a horizontal line.

Poul Villien
Coordinating Manager