

# **Compliance Statement**

No. 2014-039

## Data communication cords, Category 6A

#### Company

KRUGEL EXIM spol. s r.o. Rybničná 38/H 831 06 Bratislava Slovak Republic

#### **Product description**

Screened Category 6<sub>A</sub> RJ45 cords (equipment, patch, and work area) characterised up to 500 MHz

#### **Product identification**

KELine 10Giga patch cables STP Cat.6A, LS0H Part number: KEL-C6A-P-xxx (xxx: denotes length in dm)

### Generic cabling and cabling components standard - Category 6<sub>A</sub> balanced cord requirements

- ISO/IEC 11801:2011 (Ed. 2.2)
- EN 50173-1:2011
- EN 50173-2:2007 including amendment A1:2010
- ANSI/TIA-568-C.2:2009
- IEC 61935-2:2010 (Ed. 3.0) (transmission requirements)

Technical report DELTA-T207463, DANAK-19/13680 EC Cabling product ID

CS valid until 1 March 2015

This product has been tested by DELTA EC Cabling Group and complies with the requirements of the above specified standards and "Terms and conditions for the EC VERIFIED programme for Generic and Coaxial Cabling", DQP231006. The product takes part in a maintenance of certification schedule, which implies that DELTA EC Cabling performs a sample test of the product once a year.

Hørsholm, 21 January 2014

Lars Lindskov Pedersen

Test Manager

Claude Videt Project Manager

Vicut

**DELTA** 

Venlighedsvej 4 2970 Hørsholm Denmark Tel. +45 72 19 40 00 Fax +45 72 19 40 01 www.madebydelta.com/cable

